



EDUCATION DEPARTMENT  
GOVERNMENT OF SIKKIM  
GANGTOK

Memo No. - 128/DIV/GTK/EDN/GOS

Date- 23 /04/2024


**BUILDING SAFETY CERTIFICATE**

This is to Certify that the physical inspection of **Bahai Senior Secondary School, having CBSE Affiliation No.1820100, School code No. 39484,** located at Saramsa, Ranipool in East Sikkim, was conducted on 16<sup>th</sup> of April 2024 by the field engineer of Education Department (Gangtok), where it was found that the above-mentioned school has two numbers of R.C.C. framed structures and 1 number of Semi pucca Structure with the following details as mentioned below: -

1. **Block A** - 4 storeyed R.C.C building with 18 classrooms.  
The built-in plinth area is 3,680ft<sup>2</sup>.
2. **Block B** - 1 storeyed R.C.C building with 4 rooms, 1each for Library, Computer Lab, Infirmary and Book store.  
The built-in plinth area is 4,225ft<sup>2</sup>.
3. **Block C (Primary Section)** - 1 storeyed semi pucca building with 3 class rooms.  
The built-in plinth area is 976ft<sup>2</sup>.


The visual inspection revealed that the columns, beam and slabs have no cracks or shear stress of any kind, the partition were also found to be free from cracks, till date the school buildings has no significant damages and defects, hence, the structures can be certified to be fairly safe.

**This Certificate is valid for a period of one year from the date of issue.**

  
Assistant Engineer,  
Assistant Engineer (East),  
Education Department,  
Sub-Division (Gangtok),  
GOVERNMENT OF SIKKIM,  
Govt. of Sikkim.

Superintending Engineer,  
Education Department,  
Sub- Division (Gangtok),  
Govt. of Sikkim.

  
Manager  
BAHAI SCHOOL  
SARAMSA

  
Principal  
Bahai Senior Secondary School  
Saramsa